


TWO STAGE PRIMARY SETTLEMENT

ELEVATION



AERATION ZONE 1 & 2 / FINAL SETTLEMENT

PLAN

Notes

1. Do not scale directly from drawing
2. Dimensions are in mm unless otherwise stated
3. Inlet Pipe Invert at 0.925m below ground level (99.075)
4. Turret heights vary across the plant as indicated
5. Access Turrets Positions as shown
6. Inlet & Outlet Pipework to plant 150mm NB Underground UPVC Drainage Pipe
7. Main Turret contains 3 no. 900 x 900 Access Manways
8. Covers - GRP PD
9. Allowance for covers ending flush with GL
10. Ground Level taken as 100.00 OD at inlet position
11. If in doubt on any issue ask

Rev.	DESCRIPTION	DATE		
<p>Synergy WASTEWATER TREATMENT P R O D U C T S</p>				
<p>CROOM, ENMORE ROAD ENMORE BRIDGWATER SOMERSET TA5 2AN</p> <p>Phone: 0044 (0)1278 671927 Fax: 0044 (0)1278 671963 E-mail: info@synergy-wtp.co.uk Web: www.synergy-wtp.co.uk</p>				
Project				
Client				
Drawing Title				
<p>BIOLOGICAL AERATED SEWAGE TREATMENT PLANT</p>				
Date	Scale (A4)	Drawn by	Checked by	Approved by
02.10.08	NTS	GD	MN	AB
Status	FOR APPROVAL	FOR CONSTRUCTION	AS BUILT	Drawg. No.
PLANNING <input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	P200 G
TENDER <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	